

SPECIFICATIONS “HOL” HISTORIC ONE LITE

APPLICATION: EXTERIOR INSTALLATION: INSERTS REMOVE DIRECTLY TO INTERIOR

PART 1 – GENERAL

1.1 SCOPE. All aluminum windows of the types and sizes shown in the plans and/or as called for in this specification shall be furnished with all necessary hardware, fasteners and miscellaneous equipment as herein specified and shall be manufactured by Allied Window, Inc. Quality standards shall be as described within these specifications.

PART 2 – MATERIALS

2.1 ALLOYS. Aluminum shall be of commercial quality and of proper alloy for window construction free from defects impairing strength and durability. All straight extruded sections shall be of 6063-T5 alloy and temper and shall have a minimum ultimate tensile strength of 22,000 P.S.I. and a yield of 16,000 P.S.I.

2.2 WINDOW MEMBERS. Master frame members shall be of extruded aluminum with a 3/8” x 1 3/8” dimension. All extrusions shall be of sufficient strength to perform as designed. Window members shall have a nominal wall thickness of not less than .062”. All corner keys shall be of extruded aluminum.

2.3 FASTENERS. All screws and other miscellaneous fastening devices incorporated shall be stainless steel or other non-corrosive metals compatible with aluminum.

2.4 HARDWARE. All insert clips shall be nylon, or zinc die cast.

PART 3 – CONSTRUCTION

3.1 ASSEMBLY. All windows shall be assembled in a secure and workmanlike manner. The master frame and insert frame(s) shall be of mitered head and sill. Frame rails and stiles shall be neatly joined together using extruded aluminum corner keys staked in place.

3.2 SILL EXPANDER. Sill expander shall be of “H” type with minimum wall thickness of .062” and .125” web thickness, and modified to permit weepage.

3.3 INSERTS. Insert(s) shall be freely removable and equipped with a full bottom rail lift handle. Insert(s) held in place by cam action clips.

3.4 HARDWARE. Latching clips shall have cam action and provide positive seal between master frame and insert(s). NO hardware shall be visible on exterior of units.

PART 4 – FINISH

The exposed surfaces of all aluminum members shall be clean and free from serious surface blemishes. Standard finishes shall be mill finish or electrostatically applied baked acrylic enamel in white, colonial white, beige, black or bronze. Painted finish shall meet AAMA 2603. Optional custom color finish to be two-part polyurethane paint (air dried). Clear anodized, bronze anodized and Kynar–equivalent finishes are available under appropriate circumstances.

PART 5 – SCREEN(S) (Optional)

Extruded screen insert frame(s) (3/8" x 1 1/16") with extruded aluminum corner keys shall be provided. Standard screen cloth is charcoal aluminum 18 x 16 mesh securely held in frame with vinyl spline (fiberglass, black aluminum, bright aluminum, stainless steel, or bronze screen wire optional).

PART 6 – GLASS AND GLAZING

6.1 GLASS. Glass shall be not less than “B” quality. Standard factory glazing shall be “DSB” (1/8”). Optional use of 5/32”, 3/16”, or tempered glass shall be dictated by size of panels, code requirements, or project specifications.

6.2 GLAZING MATERIAL. Glass shall be held in place with removable and reusable vinyl glazing splines. Vinyl shall be manufactured from virgin polyvinyl chloride. All corners shall be neatly mitered.

PART 7 – INSTALLATION

The installer shall securely fasten windows in place to a straight, plumb and level condition, without distortion of the windows and shall make final adjustments for proper operation in accordance with the manufacturer’s instructions. Exterior storm windows are provided with high quality Mylar foam tape at the head and jambs, to make caulking unnecessary, and provide for future removal.

PART 8 – WARRANTY

Manufacturer shall provide a five (5) year warranty against faulty materials, paint and workmanship.

SPECIFICATIONS SUBJECT TO CHANGE WITHOUT NOTICE.

For More Information Contact:

ALLIED WINDOW, INC.
11111 Canal Road
Cincinnati, Ohio 45241
(800) 445-5411
(513) 559-1212
(513) 559-1883 (Fax)

WEBSITE
www.alliedwindow.com
www.invisiblestorms.com

E-MAIL ADDRESS
info@alliedwindow.com

HOL 10/19